

## GENERATORS:

- Installed per manufacturer's instruction
- Not within 20 feet of tent
- Placed on a noncombustible surface



Fire District 3  
Jackson County, OR

# Vendor Safety Checklist

## FIRE EXTINGUISHERS\*:



- Easily assessable
  - Class K extinguisher available if needed
  - Current inspection tag
  - Not fueled while running or hot
  - Isolated from the public
  - Clear of vegetation and brush
- \* Only applies if an ignition source exists



Contact Us:



541-826-7100



8383 Agate Road  
White City, OR 97503



www.JCFD3.com  
firemarshalsoffice@jcfcd3.com



### COOKING SAFETY:

- Cooking equipment using oils shall have a noncombustible lid
- Class K extinguisher available
- LPG tanks at least 10 feet from tent
- LPG tank tip over protection provided
- LPG tanks protected from vehicle traffic
- LPG connections checked for leaks
- LPG relief valve pointed away from tent

### EXTENSION CORDS:

- Power Taps shall be UL 1363 listed and labeled
- Extension Cords shall be UL 817 listed and labeled
- Grounded and polarized



- Not subjected to damage
- Listed for outdoor use
- Sized for required current draw



### TENT GUIDELINES:

- CPIA84 or NFPA701 approved and labeled
- Erected per manufactures instructions
- Used less than 180 days
- Clear of vegetation and brush
- Two exits if more than 10 occupants
- Located away from vehicle exhaust